



Ref. Certif. No.

HU-005648

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCB(Circuit-breakers for overcurrent protection)

Name and address of the applicant

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, 325604
Zhejiang, P.R. China

Name and address of the manufacturer

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, 325604
Zhejiang, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co., Ltd. (Yueqing Economic
Development Zone Branch) No.288 Central Avenue Development
Zone, Yueqing City, 325604 Zhejiang, P.R. China

Ratings and principal characteristics

In: 6/10/16/20/25/32/40A; B-/C-/D-Type;
Ue:220/230/240V~(1P+N);50/60Hz;
Ics=Icn:6kA;Uimp:4kV;Ui:500V;
Reference ambient air temperature:+30°C

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGB3-40

Additional information (if necessary may also be
reported on page 2)

N/A

A sample of the product was tested and found
to be in conformity withIEC 60898-1:2015+A1
See Test Report for National DifferencesAs shown in the Test Report Ref. No. which
forms part of this Certificate

CN25VEVM 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2025-06-13

Signature:

Wencai Zhang